



DO NOT SCALE

DRAWING NO.		D02022003403	
DRWN	IK	CHKD	CA
REVISION		DATE	DETAILS

**CT WIRING DIAGRAM FOR MULTIPLE BLUEWAVE WITH CTs DOWNSTREAM**

additional information is available at [www.bluewaveuk.com](http://www.bluewaveuk.com)

**PQM**

Power Quality Management Ltd  
 PO Box 76  
 Blakeney  
 Gloucestershire GL15 4DE

t 01594 510670  
 f 01594 516170  
 e [info@pqmanagement.co.uk](mailto:info@pqmanagement.co.uk)  
 www.pqmanagement.co.uk

- NOTES**
1. Ensure P1 and P2 (K and L) are facing as shown.
  2. A CT shorting facility must be provided before terminating at the Active Filter.
  2. For multiple incoming supplies contact us.