



NOTES
 1. 5A secondary CTs input terminals are adjacent to power cable terminals
 2. A CT shorting facility must be provided before terminating to the Active Filter
 3. See www.bluewaveuk.com for more installation support information



Power Quality Management Ltd
 PO Box 76
 Blakeney
 Gloucestershire GL15 4DE
 t 01594 510670
 f 01594 516170
 e info@pqmanagement.co.uk
www.pqmanagement.co.uk

BLUEWAVE ACTIVE HARMONIC FILTER
100A 3-WIRE IP20
 more product information is available from:
www.bluewaveuk.com

WEIGHT 80Kg
VENTILATION 1400m³/h

DO NOT SCALE
 DRAWING NO. D02022100320

DRWN	IK	CHKD	CA	Date	15-04-08
REVISION		DATE	DETAILS		