



NOTES

1. A CT shorting facility must be provided before terminating to the Active Filter.
2. See www.bluewaveuk.com for more installation support information



Power Quality Management Ltd
 PO Box 76
 Blakeney
 Gloucestershire GL15 4DE
 t 01594 510670
 f 01594 516170
 e info@pqmanagement.co.uk
www.pqmanagement.co.uk

BLUEWAVE ACTIVE HARMONIC FILTER
300A 3-4 WIRE IP54

WEIGHT 395Kg
VENTILATION 3600m³/h
 more product information
 is available from:
www.bluewaveuk.com

DO NOT SCALE

DRAWING NO. D020223003454

DRWIN	IK	CHKD	CA	Date
				15-04-08
REVISION		DATE	DETAILS	